

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 3242-1130:0277

CATEGORY: 3242 -- DUCT SMOKE DETECTOR, PHOTO. (W/ OR W/O BASE)

LISTEE: Honeywell International Inc. 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Deo Supanavongs (847) 797-4217 Fax (847) 797-3664
Email: deo.supanavongs@honeywell.com

DESIGN: Model HFS-D analog photoelectric duct smoke detector housing. The unit consists of a duct detector housing, exhaust tubes, and separately listed compatible detector head. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, air velocity and UL label.

APPROVAL: Listed as a duct detector unit when used with listee's separately listed compatible fire alarm control units. Suitable for use in ducts where air velocities varies between 100-4000 FPM. Refer to listee's Installation Instruction Manual for details.

XLF: 3242-1653:0209

02-02-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division