

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-1130:0276

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: HONEYWELL INTERNATIONAL INC., 12 Clintonville Road, Northford, CT 06472
Contact: Yogesh Shah (203) 484-1200 Fax (203) 484-7309
Email: yogesh.shah@honeywell.com

DESIGN: Models HFS-T heat detector. Model HFS-T is a 135°F fixed temperature detector. Refer to listee's data sheet for detailed model descriptions and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee name, model number, electrical rating, and UL label.

APPROVAL: Listed as heat detector for use with listee's separately listed compatible bases and fire alarm control units.

02-02-2010 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division