

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-1130:0278

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Honeywell International Inc. 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Deo Supanavongs (847) 797-4217 Fax (847) 797-3664
Email: deo.supanavongs@honeywell.com

DESIGN: Models HFS-MM Monitor Module and HFS-MR Relay Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary operating supply:
HFS-MM 15-32 VDC, 600 uA
HFS-MR 15-32 VDC, 6.5 mA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as monitor module and relay module accessories for use with listee's separately listed compatible fire alarm control units.

01-28-2010 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division