



Listing Constructional Data Report (CDR)

1.0 Reference and Address			
Report Number	3189837NYM-001a	Original Issued: 25-Jan-2010	Revised: None
Standard(s)	Standard for Safety for Control Units and Accessories for Fire Alarm Systems, ANSI/UL 864 9th Edition, Issued 9/30/2003, Revised 5/29/2007; Standard for Control Units for Fire Alarm Systems, ULC S527, Second Edition, Dated June 1999; Standard for Control Units for Fire Alarm Systems, ULC S559, First Edition, Dated May 2004		
Applicant	Silent Knight a Honeywell Company	Manufacturer	Honeywell
Address	7550 Meridian Circle Suite 100 Maple Grove, MN 55369-4929	Address	12 Clintonville Road Northford, CT 06472-1610
Country	USA	Country	USA
Contact	Mr. Mike McIsaac	Contact	Yogesh Shah
Phone	(763) 463-4144	Phone	(203) 484-6394
FAX	(612) 493-6475	FAX	(203) 484-7309
Email	mike.mcisaac@honeywell.com	Email	Yogesh.Shah@Honeywell.com

2.0 Product Description	
Product	Fire Alarm Control Panel
Brand name	Silent Knight
Description	The product covered by this report is a communicating fire alarm control panel that is permanently connected to the branch circuit supply. It has one SLC loop that can support up to 25 accessories, two NAC circuit, three relay outputs (one trouble and two programmable) and two phone connections. There is also an ethernet programming port used for configuration only.
Models	5600, 5600HV, IPF-25
Model Similarity	N/A
Ratings	120V, 60Hz, 1.5A and 230V, 50/60/Hz, 0.75A
Other Ratings	N/A