

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-0559:0172 Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** SILENT KNIGHT SECURITY 1985 Douglas Drive, MN10-212A, Golden Valley, MN 55422  
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464  
Email: mike.mcisaac@honeywell.com

**DESIGN:** Model 5820XL-EVS Fire Alarm Control Unit. Automatic, manual, local, remote station (PPU), central station (PPU), releasing (water deluge only) and mass notification services. Refer to listee's data sheet for additional detailed product description and operational considerations.

System components:

- 5820XL-EVS; Control unit
- 5820XL-EVSCCB; Enclosure
- EVS-RCU; Remote command unit
- EVS-50W, EVS-125W; Amplifiers
- EVS-RVM; Remote voice module
- EVS-VCM; Voice control module
- EVS-SW24; Switch expander
- EVS-CE4; Speaker expander module
- EVS-100W
- EVS-WBU

**RATING:** 120V, 60HZ

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as commercial fire alarm control unit for use with separately listed initiating and indicating devices and for mass notification. Refer to listee's Installation Instruction Manual for details.

**NOTE:** For Fire Alarm Verification feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds

09-25-14 jp



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division