

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0559:145 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: *Michael Mc Isaac (763) 493-6400 FAX (763) 391-5464

DESIGN: Models SK-2 and SK-4 fire alarm control units. Model SK-2 suitable for local, central station and proprietary (protected premises). Model SK-4 suitable for non-coded; local, remote station, auxiliary, proprietary (protected premises) and central station (protected premises) when used with appropriate option modules and additional separate listed equipment; automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

SK-2, -4	Control Unit
SK-4XTM	Transmission Module
SK-CAC4	Converter Module
SK-4XZM	Zone Relay Module
SK-4XLM	LED Interface Module
SK-RZA4	Remote Zone Annunciator
SK-XRM24	100 VA Transformer

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and indicating devices. This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002. Refer to manufacturer's Installation Manual for details.

This control unit meets the requirements of UL-864, 8th Edition Standards.

NOTE: For *Fire Alarm Verification* feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds

XLFF: 7165-075:200

*Rev. 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

Listing Expires June 30, 2009

Authorized By: **BEN HO, Chief**
Fire Engineering Division