



UQGS.S6228

Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)

SILENT KNIGHT

S6228

HONEYWELL CO

7550 MERIDIAN CIR

MAPLE GROVE, MN 55369 USA

Type	Temp Rating F	Smooth Ceiling Spacings		Contact Arrangement	Model No.
		Between Detector	to Wall or Partition		
FT	135-150	70	25	Not Appli- cable	SD505-AHS
Base Model No.			Related Detector		
SD505-6AB			SD505-APS		

FT: Fixed temperature.

[Last Updated](#) on 1998-12-22

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

