



AMCX.S2766

## Central Station Alarm Units

### [See General Information for Central Station Alarm Units](#)

#### **SILENT KNIGHT**

S2766

#### **HONEYWELL CO**

7550 MERIDIAN CIR

MAPLE GROVE, MN 55369 USA

Digital alarm communicator system. Consists of Models 8510, 8520 digital alarm communicator receivers, Model 8530 power supply unit.

Digital alarm communicator system, Model 9000 digital receiver and Model 9001 line expander module. Intended for use with compatible Listed digital alarm communicator transmitters. Suitable for Grade C service.

Digital alarm communicator, Model 9800, 9850 digital receiver. Intended for use with compatible Listed digital alarm communicator transmitters. Suitable for Grade C service.

Enclosures, Models 3890, 4890.

Printer, Model SK320.

Control unit accessories: Models 4126 zone expander, 4140 intercom/telephone controller, 4145 intercom station, 4180 status display module, 5255 on site printer, 4724 expander intended for use with the Model 4720 control unit. Model 4723 control unit with 4660C keystations, intended for use with compatible Listed DACRs as recommended in the installation instructions. Suitable for Grade C service. Suitable for Grade B service when connected to a Listed Ademco AB-12 bell housing with Ademco Model AD10-12 or Wheelock Model 46TG-10 bell. Suitable for Grade AA service when installed in accordance with the installation instructions with the Listed Ademco 7920SE transceiver.

Models 4820, 4821, MAC-400 control units for use with separately Listed devices as indicated in the installation instructions. Suitable for Grades B and C service, Grade B service requires AB-12 bell and bell housing.

Subassembly, Models 4875 phone line module and 4195 auxiliary power supply for use with Models 4820, 4821, MAC-400 .

Subassembly, Model 4875 phone line module for use with Models 4820, 4821, MAC-400.

Subassembly, Model 9859 assembly 9810 one line card, 9860 three line card, 9861 radio line card, intended for use with the 9850 DACR as recommended in the installation instructions.

Accessories, Models 4815 serial zone expander, 4825 zone expander, 4824 serial-parallel interface, 4880 output module, 4860C and 4860R keypads for use with Models 4820, 4821, MAC-400 .

Model 4821CB, MAC-400 enclosure for use with the Model 4821.

**Last Updated** on 2002-06-18

---

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

