



UROX.S6173

## Smoke-Automatic Fire Detectors

[See General Information for Smoke-Automatic Fire Detectors](#)

**SILENT KNIGHT**

S6173

**HONEYWELL CO**

7550 MERIDIAN CIR

MAPLE GROVE, MN 55369 USA

Application	Type	Compatibility Restriction	Velocity		Model
			Range Min	(fpm) Max	
OAP	P	++	0	300	SD400-CPS
OAP	I	+	0	300	SD505-AIS
OAP	P	+	0	300	SD505-APS
D(ST)	I	+	300	4000	SD505-ADH
					(W/SD505-AIS)
D(ST)	P	+	500	4000	SD505-ADH
					(W/SD505-APS)
D(ST)	I	+	300	4000	SD505-ADHR
					(W/SD505-AIS)
D(ST)	P	+	500	4000	SD505-ADHR
					(W/SD505-APS)
Base Model No.	Related Detector		Control Unit Compatibility Restriction		
SD505-4AB	SD505-AIS, -APS		+		
SD505-6AB	SD505-AIS, -APS		+		
SD505-6SB	SD505-AIS,		(+) (+)		
	-APS, AHS				

SD505-6RB	SD505-AIS,	(+)
	-APS, AHS	

+ -For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible Models indicated on installation wiring diagram for Detector (Base) and/or control units.

++ -Certain bases provide two-wire connections and Listing is limited to specific system control units. Information on compatible control units is indicated on the installation drawing of the control unit and/or detector .

D(ST)-Duct detector-sampling tubes.

I-Ionization.

OAP-Open area protection.

P-Photoelectric.

[Last Updated](#) on 2000-04-07

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

