

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 3240-0559:139

Page 1 of 1

**CATEGORY:** Duct smoke Detector Housing/Base

**LISTEE:** Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369  
Contact: \*Michael Mc Isaac (763) 493-6400 FAX (763) 391-5464

**DESIGN:** Models SD505-ADHR duct smoke detector housing with relay and SD-505-DTS detector test station. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, and UL label.

**APPROVAL:** Listed as a duct smoke detector housing/base and test station for use only with listee's separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

\*Rev. 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*