

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0559:132 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369  
Contact: \*Michael Mc Isaac (763) 493-6400 FAX (763) 391-5464

**DESIGN:** Models SD500-FRCM, SD500-FRCM-4 Monitor Modules and Model SD505-ARM Relay Module.

Models SD500-ARM, SD500-AIM, SD500-MIM Addressable Input Modules.

Models SD500-FRCM and SD500-FRCM-4 monitor modules provide inputs for a control unit communication circuit and one Style B (Class B) contact closure initiating device circuits.

Models SD505-ARM and SD500-ARM provide inputs for a control unit communication circuit and have two sets of dry relay contacts. Models SD500-AIM and -MIM provide additional input circuits.

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** SD500-FRCM, -FRCM-4, -ARM, -AIM, -MIM: 24 VDC  
SD505-ARM: 120 VAC, 30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XL:** 7300-0410:145

\*Rev. 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division