

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-0559:136

Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: Michael Mc Isaac (763) 493-6400 FAX (763) 391-5464

DESIGN: Model PS-SKSA and SD500-PS fire alarm pull boxes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm pull station use with separately listed compatible fire alarm control units. For indoor use only.

* These manual pull boxes do not meet the requirements of UL Standard 38, 1999 Edition and California amendments.

*Updated 06-22-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 30, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division