

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0559:141

Page 1 of 1

CATEGORY: Voice Communication Systems Control Units

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: *Michael Mc Isaac (763) 493-6400 FAX (763) 391-5464

DESIGN: Model SKE-426 and SKE-450, *-ZN4, *-ZN6 Voice Evacuation Systems. Power limited. The unit is a single channel, automatic or manual voice evacuation/emergency message panel. The unit is intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for detailed product description and operational considerations. System components:

SKE-426, -450, *-B450	Main Board
SKE-ZN4	4-Zone Splitter Module
SKE-ZN6	6-Zone Splitter Module
SKE-PS3	Power Supply Module
SKE-V70	Speaker Card
SKE-SRM	Remote Microphone

RATING: Input: 120 VAC, 240VAC, Standby: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a voice evacuation system for use with a separately listed electrically compatible fire alarm control units.

This control unit can generate a distinctive three pulse temporal fire alarm evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

*Rev. 04-21-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

Listing Expires June 30, 2009

Authorized By: **BEN HO, Chief**
Fire Engineering Division