



April 12, 2001

Silent Knight  
Mr. Brian Foltz  
7550 Meridian Circle, Suite 100  
Maple Grove, MN 55369

Reference: S2766, 01NK16900

Subject: Remote Reset or Silence Switch

Dear Brian:

This is a follow up to your fax dated March 26, 2001 with reference to the above subject.

A remote reset and/or silence switch can be used on the Silent Knight SK-5208 control panel provided the following provisions are met. UL has verified the operation of this feature and has found it to be in compliance with UL 864.

1. The switch is wired into a supervised input on the panel with an end-of-line resistor used to maintain supervision. In lieu of using a Listed EOL, one could be used that meets the construction requirements of UL 864.
2. The maximum loop resistance does not exceed 50 ohms.
3. The remote switch is placed in a locked enclosure that is UL 864 Listed. The switch could also be placed in a UL Listed electrical box provided its access is key-lock protected.
4. The input zone being used for remote reset or silence is programmed for this function.

A project was established to cover this investigation. Therefore, this letter acts to close Project No. 01NK16900 and our Accounting Department will be instructed to bill you for the charges incurred. Should you have any questions, please do not hesitate to contact me.

Sincerely,

A handwritten signature in cursive script that reads "David Stone".

David Stone (ext. 43387)  
Conformity Assessment Services

Reviewed by

A handwritten signature in cursive script that reads "D. H. Brunmeier".

D. H. Brunmeier  
Conformity Assessment Services