

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0559:0171 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: SILENT KNIGHT SECURITY 1985 Douglas Drive, MN10-212A, Golden Valley, MN 55422
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Model 5496 Intelligent power module.
The power module consists of the following:
Model 054960; main board
Model 122599; enclosure
Model SK-F485C; fiber to sbus converter

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 Vac

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a power module for use with listee's Models 5820XL and IFP-1000 (CSFM No. 7165-0559-135), 5808 and IFP-100 (CSFM No. 7165-0559-142), IFP-50 and 5700 (CSFM No. 7165-0559-144), IFP-100ECS and IFP-1000ECS (CSFM No. 7165-0559-169) fire alarm control units. Refer to listee's Installation Instruction Manual for details.

03-06-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division