## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





**LISTING No.** 7165-0559:0137 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: SILENT KNIGHT SECURITY1985 Douglas Drive, MN10-212A, Golden Valley, MN 55422

Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464

Email: mike.mcisaac@honeywell.com

**DESIGN:** Model SK-5208 fire alarm control unit. Power-limited, automatic, manual, remote station,

central station, waterflow, Releasing Device Service, and sprinkler supervisory services. Refer

to listee's data sheet for additional detailed product description and operational

considerations. System components:

SK5208 Control Unit

SK-5220 Direct Connect Module SK-5280 Status Display Module SK-5217 Zone Expander SK-5235 Remote Annunciator

SK-2190 Enclosure SK-7181 Zone Converter

**RATING:** 

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and

indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to

manufacturer's Installation Manual for details.

This control unit meets the requirements of UL-864, 9th Edition Standards.

NOTE: 1. For the Alarm Verification Feature (delay of fire alarm), the maximum

Retard/Reset/Restart shall not exceed 30 seconds.

2. Burglary and other non-fire functions were not examined.

08-17-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2016 Listing Expires June 30, 2017

Authorized By: DAVID CASTILLO, Program Coordinator

Fire Engineering Division