

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0559:0142

Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: SILENT KNIGHT SECURITY 1985 Douglas Drive, MN10-212A, Golden Valley, MN 55422
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models *5808, *IFP-100 Fire Alarm Control Units. Power limited, automatic, manual, local, remote station, central station, waterflow, water releasing and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

5808, IFP-100	Control Units
*01FP-100BD	Motherboard
7628	EOL Resistor
5860/5860R/RA-1000	Annunciator
*0IFP100-IA IFP-100	User Interface
*058631 5808	User Interface
5496	Power Module
5824	Serial/Parallel Interface
RPS-1000	Power Expander/Supply
5865-3/5965-4	LED Annunciator
5880 LED IO	Module
5883	Relay Interface Board
SD500-ANM	Addressable Notification Module
SD500-LIM	Line Isolation Module
SD505-6IB	Isolation Base
SD-500 SDM	Smoke Detector Module
RA-100	Remote Annunciator
3158	Reverse Polarity Module
5220	Direct Connect Module
*122740, *122723E	Enclosures

RATING: 120 VAC Primary, 24 VDC Secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

Rev. 10-3-08 ma



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division

This control unit meets the requirements of UL-864, 9th Edition Standards.

NOTE:

For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

Rev. 10-3-08 ma



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division