

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-0559:0165 Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** SILENT KNIGHT SECURITY 1985 Douglas Drive, MN10-212A, Golden Valley, MN 55422  
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464  
Email: mike.mcisaac@honeywell.com

**DESIGN:** Models 5600, 5600HV, IFP-25 and IFP-25HV Fire Alarm Control Units. Automatic, manual, waterflow, sprinkler supervisory, local, remote station (PPU), central station (PPU) services. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

5220                      Direct Connect Module  
IPDACT2UD          IP DACT  
HFS-MR                  Reverse Polarity  
\*5635                  Remote Annunciator

**RATING:** 120 VAC or 230 VAC Primary, 24 VDC Secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as commercial fire alarm control unit for use with separately listed initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition and meets the requirements of UL Standard 864, 9th Edition.

08-08-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*