



**SILENT
KNIGHT**

by Honeywell

FFT-24 Installation Instructions

The FFT-24 expander board lets you add 24 additional zones to the Fire Fighter Telephone.

Compatibility

The FFT-24 is compatible with Silent Knight FFT series Fire Fighters Telephone. For more information refer to the IFP-FFT installation manual 54708 or the SK-FFT installation manual 54711.

Mounting

1. Open Cabinet door and dead front panel.
2. Remove power from compatible powering device.
3. Remove existing cover plate.
4. Mount the FFT-24 on the six mounting studs located on the inside of the dead front panel and secure using the nuts provided with the FFT-24.




Figure 1: Mounting Location for the FFT-24

Wiring

1. Connect one end of the wiring harness (P/N 130398 supplied) to the FFT and the other end to the FFT-24 as shown in Figure 2.




Figure 2: Wire Harness connection

2. Restore Power.



**SILENT
KNIGHT**

by Honeywell

12 Clintonville Road
Northford, CT 06472-1610 USA
203-484-7161
Fax: 203-484-7118
www.silentknight.com

© 2011 Honeywell International Inc.

P/N 54421 Rev A
ECN 11-0003